



The Public Health and Safety Organization

NSF Product and Service Listings

These NSF Official Listings are current as of Tuesday, April 05, 2016 at 12:15 a.m. Eastern Time. Please [contact NSF International](#) to confirm the status of any Listing, report errors, or make suggestions.

Alert: NSF is concerned about fraudulent downloading and manipulation of website text. Always confirm this information by clicking on the below link for the most accurate information: <http://info.nsf.org/Certified/PwsComponents/Listings.asp?Company=1P550&Standard=061&>

NSF/ANSI 61 Drinking Water System Components - Health Effects

NOTE: Unless otherwise indicated for Materials, Certification is only for the Water Contact Material shown in the Listing. Click here for a list of [Abbreviations used in these Listings](#). Click here for the definitions of [Water Contact Temperatures denoted in these Listings](#).

Penetron International, Ltd.

45 Research Way
Suite 203
East Setauket, NY 11733
United States
631-941-9700
[Visit this company's website](#)

Facility : Allentown, PA

Protective (Barrier) Materials

Trade Designation	Water Contact Size Restriction	Water Contact Temp	Water Contact Material
Coatings - Pipe Penetron[1] [2]	>= 36"	CLD 23	CMNT

[1] Number of Coats: 1-2
Sequence of Coats: N/A
Maximum Field Use Dry Film Thickness (in mils): 200
Maximum Thinner: None

Recoat Cure Time and Temperature: Immediate
Final Cure Time and Temperature: 48 hours at ambient temperature
Special Comments: 2.0 parts powder is mixed with 0.8 parts water, by volume, to make the coating

[2] Certified for use as a crack or void repair material. Repaired area not to exceed 5% of the surface area for pipes 4" and greater and for tanks 1,000 gallons and greater.

Coatings - Tank

Penetron[1] [2]	>= 2000 gal.	CLD 23	CMNT
-----------------	--------------	--------	------

[1] Number of Coats: 1-2
Sequence of Coats: N/A
Maximum Field Use Dry Film Thickness (in mils): 200
Maximum Thinner: None
Recoat Cure Time and Temperature: Immediate
Final Cure Time and Temperature: 48 hours at ambient temperature
Special Comments: 2.0 parts powder is mixed with 0.8 parts water, by volume, to make the coating

[2] Certified for use as a crack or void repair material. Repaired area not to exceed 5% of the surface area for pipes 4" and greater and for tanks 1,000 gallons and greater.

Concrete Admixtures

PENETRON ADMIX	[3]	CLD 23	CMNT
Penetron Admix with Tracer	[3]	CLD 23	CMNT

[3] Certified for a level not to exceed 1% by mass of cement.
Certified for use in pipes 1/2" and greater, tanks 1,000 gallons and greater.

Number of matching Manufacturers is 1
Number of matching Products is 4
Processing time was 0 seconds